BANGALORE WATER SUPPLY AND SEWERAGE BOARD

). BWSSB/CEDTE/ACE(MIS)/TA(Design& QA)//2024-25 Dt:Office of the Chief Engineer (Design& QA),Cauvery Bhavan, Bangalore-560009

ADDENDUM-I TO TENDER THROUGH KARNATAKA PUBLIC PROCUREMENT PORTAL ONLY

(www.kppp.karnataka.gov.in)

Ref:-NITNo.:BWSSB/CED&QA/ACE(Design)/ TA/2121/2024-25 Dated:06.11.2024

****

In continuation of the above tender notification was invited vide reference, with respect to Technical Schedule of Work of supply, erection, and commissioning of 2 Nos 250HP and 1Nos of 240HP HSC pump set and allied works at Cauvery pump house at HGR premises coming under the AEE (DE&PS)-1 subdivisionan addendum-I is issued as follows:

Sl.No.	Firm Name	Queries Received	Query Response
1	**M/s.Flow More Limited**	1) Pl confirm the existing Transformer at the site	• There are 2 nos of 1000KVA transformer
		2) Metering cubicle CT's to be replaced if it is new type Metering cubicle, else new metering cubicle to be installed. Pl clarify	• No replacement of Cts and Pts
		3) Since the project is involved with 1000 KVA Transformer, CEIG Commissiong approval to be obtained mandatorily. Since the CEIG inspection is involved, Tool Kit, Fire fighting Equipment's & earthing materials are to installed as per IE Rule which are mandatory. Above equipment's are not considered in the Tender BOQ. Pl clarify	• Safetv equipments are present in the pumphouses.

		4) It will helpful if the rating of dismantling pump set is mentioned, to get clarity of the existing Control panel & Starter is suitable. Pl clarify	• Existing control panel and starter are as per the required pumpset capacity.
		5) As per Tender Clause Section 9 it has been mentioned that prices should be exclusive of GST but as per price bid it has been mentioned that prices should be inclusive of all applicable Taxes Pl clarify	• As per the GO ಸುತ್ತೋಲೆ ಸಂ.ಆಇ417 ಪೆಚ್ಚ-12/2024 ದಿನಾಂಕ:09.08.2024 Tender is invited with exluding GST.Tenderer should quote the rate excluding GST.
		6) Payment Terms not mentioned in the Bid, Pl clarify	• Payment condition remain same as per bid document
		7) Since we are Electrical contractor Can we submit our bid along with KPWD Contractor consent Letter, Pl note min civil work for Pumps Foundation are involved, Pl clarify whether KPWD License is required to unload	• Contractors should have **Electrical license** (Class I) in KSEI/KPWD or any other authorized department.
		8) As per Clause # 3.3(Page 6 of 45). OEM Manufacturer authorization letter to be submitted is mandatory for the tender. Is it mandatory for Civil, Steel & EOT Materials. Consumption of Civil &Steel materials are minimum	• OEM Manufacturer authorization letter to be submitted is mandatory for pumsets

Other conditions remain unaltered.

Chief Engineer(Design&QA)
BWSSB

NOTE: ADDENDUM-I supersedes the NIT No. BWSSB/CED&QA/ACE(DESIGN)/TA/ 373/2024-25 Dt:06.11.2024